

ŠIFRA: MBK23-090FFC-PP

ERP: 0501155

Aparat za gašenje požara 9 L s ekološkom pjenom bez fluora

Aparat za gašenje požara 9 L voda s dodatkom, s posudom s jednim šavom, unutarnji plastični sloj i sigurnosni ventil.
100% BEZ PFAS-a **UKLJUČEN METALNI NOSAČ**



KARAKTERISTIKA

Vrsta homologacije	BENOR, BSI, MED, NCP - KIWA, NF
Vrsta aparata	Prenosiv
Vrsta sredstva	Bez fluora, voda
Kapacitet	9 L
Sredstvo za gašenje	Voda s MBK LIQ FFC
Radna temperatura	5 ~+60 °C
Maksimalni dopušteni tlak	18 bar
Ispitni tlak	27 bar
Volumen spremnika	11 L
Visina cilindra	525±5 Mm
Promjer cilindra	180±1,5 Mm
Navoj vrata cilindra	M30x1,5
Materijal ventila	HPb59-1 (Nikel obložen)
Materijal cilindra	DC01 (St12)
Sigurnosni ventil	19-26 bar
Bruto težina	14,5 kg
Cca. Dimenzije	700x200 Mm
Završna obrada boje	RAL 3000



Datum izdanja: 17/04/2025

Podaci se mogu promijeniti

ŠTAB: KATHIANA AKROTIRIOU P.C. 73100 CHANIA, KRETA - GRČKA, TEL.: +30 28210 63222, FAKS :+30 28210 91644
ATENSKI DISTRIBUCIJSKI CENTAR: SHINEZA - ASPROPIRGOS, P.C. 19300, ATIKA - GRČKA, TEL.: +30 210 4614006, FAX: +30 210 5595986
DISTRIBUCIJSKI CENTAR SJEVERNE GRČKE: ARKADIOU ul. KALOCHORI - SOLUN, P.C. 57009, TEL.: +30 2310 785668, FAX: +30 2310 574793
DISTRIBUCIJSKI CENTAR SREDIŠNJE I ISTOČNE KRETE: INDUSTRIJSKA ZONA HERAKLION - KRETA - GRČKA, P.C. 71601, TEL/ FAX: +30 2810 333151

www.mobiakfire.com